

# Outdoor Distributed Energy Storage System


## Cube 1000

- Supports parallel operation of 4 cabinets and off-grid switching without communication
- Pre - installed in the factory for easy on-site installation
- Effortless operation and cloud monitoring
- The cell temperature difference  $< 5^{\circ}\text{C}$



Model	Cube 1000
<b>PCS Cabinet</b>	Monet-500TS
Rated AC Power (kW)	500 (125*4)
Rated AC Current (A)	200*4
Rated AC Voltage	400V, 3W+N+PE
DC Voltage Range (V)	580~950
Isolation Transformer (optional)(kVA)	250/500
STS (optional)(kW)	150/300/600
Protection Level	IP54
Cooling Method	Intelligent air cooling
Altitude (m)	3000 (over 2000 derating)
Dimensions (W*D*H)(mm)	1350*1000*2300
Weight (approx.)(kg)	2240
Certificates	EN50549-1,EN 62477-1,VDE V0126-1-1, NRS 097-2-1, EN 50549-1/-2 NL, IEC61000-6-2/-4
<b>PV Cabinet</b>	Monet-(DC500)
Rated Power (kW)	500 (50*10)
PV Open-circuit Voltage (V)	250-607
Max PV Input Current (A)	10*160
MPPT Quantity	10
Power Factor	-1 leading to +1 lagging
THDU	<3% (Rated power)
Protection Level	IP54
Cooling Method	Intelligent air cooling
Dimensions (W*D*H)(mm)	1350*1000*2300
Weight (approx.)(kg)	900
Certificates	EN/IEC62109-11-2, EN/IEC 61000-6-21-4
<b>Battery Cabinet</b>	GM-225.0-HPB
Rated Battery Energy (kWh)	2.25
System Rated Voltage (V)	716.8
System Voltage Range (V)	580~817.6
Series of Battery	1P*32S*7S
Cooling Method	Air conditioning cooling
Protection Level	IP54
Dimensions (W*D*H)(mm)	1000*1100*2300
Weight (approx.)(kg)	2180

Shenzhen Ruidian Green Energy Technology Co., Ltd.  4008-036-037

 Office Address: A801 Building 3A, Cloud Park, Bantian, Longgang District, Shenzhen  
 Factory Address: No.3, East Hua'nán Road, Dongjiang Hi-Tech Industrial Park, Huizhou

 [www.absenenergy.com](http://www.absenenergy.com)

